

Argonne National Laboratory (Lemont, IL) Safety Basis Report

Total Facilities: 4

Facility	Hazard Category	Safety Basis Type	Approval Status	Date Approved
Alpha-Gamma Hot Cell Facility (Bldg 212)	HC3	BIO	AUR	09/08/2015
ANL Transportation Activities	HC2	DSA	AUR	10/12/2016
WMO Facility 306	HC3	DSA	AUR	01/09/2015
WMO Facility 331	HC2	DSA	AUR	12/17/2015

Safety Basis Report current as of Dec 23, 2016

Program Office

Office of Science

Safety Basis Type

BIO – Basis for Interim Operation

DSA – Documented Safety Analysis

PDSA – Preliminary Documented Safety Analysis

Hazard Category

HC1 – Hazard Category 1 (a nuclear facility with the potential for significant off-site consequences)

HC2 – Hazard Category 2 (a nuclear facility with the potential for significant on-site consequences)

HC3 – Hazard Category 3 (a nuclear facility with the potential for only significant localized consequences)

HCR – Hazard Category Radiological (a radiological facility only)

Approval Status

AUR – Approved Under the Rule (10 CFR 830 – Nuclear Safety Management)

E – Temporary Exemption Granted

SBPA – Operating Safety Basis Pending Approval

UD – Under Development

UMR – Operating Safety Basis Pending Update to Meet the Rule